

SECTION 22 1319 - SANITARY WASTE PIPING SPECIALTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following sanitary drainage piping specialties:

- 1. Cleanouts.
- 2. Floor drains.
- 3. Through penetration firestop assemblies.
- 4. Roof flashing assemblies.
- 5. Miscellaneous sanitary drainage piping specialties.
- 6. Flashing materials. QUALITY ASSURANCE

- A. Drainage piping specialties shall bear label, stamp, or other markings of s agency.

PART 2 - PRODUCTS

2.1 CLEANOUTS

- A. Manufacturers: Subject to compliance with requirements, provide products following:

- 1. Josam Company.
- 2. Smith, Jay R. Mfg. Co.
- 3.

NORTHWESTERN UNIVERSITY
PROJECT NAME _____
JOB # _____

FOR: _____
ISSUED: 03/29/2017

2. Size: Same as connected drainage piping
3. Body Material: Hubless, cast-iron soil pipe test tee as required matching connected piping.

C. Floor Cleanouts, FCO:

1. Standard: ASME A112.36.2M for adjustable housing cleanout.
2. Size: Same as connected branch.
3. Coated cast iron internal gasketed ABS cleanout plug and adjustable ABS housing.
4. Medium-duty scoriated secured round satin finish Nikaloy top.

D. Wall Cleanouts, WCO:

1. Standard: ASME A112.36.2M. Include wall access.
2. Size: Same as connected drainage piping.
3. Round stainless steel wall access cover with screw and no-hub cleanout.

2.2 FLOOR DRAINS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Josam Company.
2. Smith, Jay R. Mfg. Co.
3. Tyler Pipe; Wade Div.
4. Zurn Plumbing Products Group.

B. Floor Drains, FD-1:

1. Standard: ASME A112.6.3.
2. Body Material: Coated cast iron.
3. Bottom Outlet with Seepage & Anchor Flange with clamping device.
4. Strainer: 6" Round Nickel bronze, Light Duty.

C. Floor Drains, FD-2:

1. Standard: ASME A112.6.3.
2. Body Material: Polypropylene.
3. Bottom Outlet with Seepage & Anchor Flange with clamping device.
4. Strainer: 5-3/16 inch round stainless steel.

2.3 THROUGH-PENETRATION FIRESTOP ASSEMBLIES

A. Through-Penetration Firestop Assemblies:

1. Refer to Firestopping and Fireproofing specifications for requirements.

2.4 ROOF FLASHING ASSEMBLIES

A.

NORTHWESTERN UNIVERSITY
PROJECT NAME _____
JOB # _____

FOR: _____
ISSUED: 03/29/2017

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Acorn Engineering Company; Elmdor/Stoneman Div.
- b. Thaler Metal Industries Ltd.

B. Description: Manufactured assembly made of 4.0-lb/sq. ft., 0.0625-inch- thick, lead flashing collar and skirt extending at least 8 inches from pipe, with galvanized-steel boot reinforcement and counterflashing fitting.

2.5 MISCELLANEOUS SANITARY DRAINAGE PIPING SPECIALTIES

A. Deep-Seal Traps:

- 1. Description: Cast-iron or bronze casting, with inlet and outlet matching connected piping and cleanout trap-seal primer valve connection.
- 2. Size: Same as connected waste piping.

- a. NPS 2: 4-inch- minimum water seal.
- b. NPS 2-1/2 and Larger: 5-inch- minimum water seal.

B. Air-Gap Fittings:

- 1. Standard: ASME A112.1.2, for fitting designed to ensure fixed, positive air gap between installed inlet and outlet piping.
- 2. Body: Bronze or cast iron.
- 3. Inlet: Opening in top of body.
- 4. Outlet: Larger than inlet.
- 5. Size: Same as connected waste piping and with inlet large enough for associated indirect waste piping.

C. Vent Caps:

- 1. Description: Cast-iron body with threaded or hub inlet and vandal-proof design. Include vented hood and setscrews to secure to vent pipe.

3.2 CONNECTIONS

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment to allow service and maintenance.

3.3 FLASHING INSTALLATION

- A. Fabricate flashing from single piece unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
 - 1. Lead Sheets: Burn joints of lead sheets 6.0-lb/sq. ft., 0.0938-inch thickness or thicker. Solder joints of lead sheets 4.0-lb/sq. ft., 0.0625-inch thickness or thinner.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
 - 1. Pipe Flashing: Sleeve type, matching pipe size, with minimum length of 10 inches, and skirt or flange extending at least 8 inches around pipe.
 - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches around sleeve.
 - 3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Install flashing for piping passing through roofs with counterflashing or commercially made flashing fittings, according to applicable Division 07 Section.
- F. Extend flashing up vent pipe passing through roofs and turn down into pipe, or secure flashing into cast-iron sleeve having calking recess.

3.4 LABELING AND IDENTIFYING

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each grease interceptor.
- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Division 22 Section "IdentificoA(op843 0 TdNH3 <</a

NORTHWESTERN UNIVERSITY
PROJECT NAME _____
JOB # _____

FOR: _____